



CITY OF GALAX
REQUEST FOR PROPOSALS
SCADA RADIO SYSTEM UPGRADE
December 3, 2024

Addendum No. 1

A. Questions received regarding this Request for Proposals. The following answers and clarification were provided.

1. What is the top end software the city uses for SCADA?
The software is In touch Window maker & viewer.
2. How many sites are needed for replacement?
5.
3. Are the sites lift stations or pump stations water plants or WWTP?
2 Pump stations & 3 tanks.
4. What are the current radios? (Brand)
No radios, they are old phone lines.
5. Are the stations within the city limits? Nothing in the county?
Yes, all stations are in the city limits.
6. What is the furthest station away and miles from the plant?
Hanes tank, it is 3 to 4 miles away from the plant.

B. The solicitation close date will remain as Thursday, December 19, 2024 at 2:00 PM.

****Acknowledgement of this addendum must be submitted with the response.**

Signature _____ Name: _____ Title: _____